

[Chapter 15.04 SUBDIVISIONS](#)

Section 15.04.560 Gravel foundation for pipe.

Wherever the subgrade material does not afford a sufficiently solid foundation to support the pipe and superimposed load, and where groundwater must be drained, the subgrade shall be excavated to such depth as may be necessary and replace with crushed rock or gravel compacted into place.

Gravel for concrete pipe foundation shall be clean crushed rock or gravel with one hundred (100) percent passing a one-inch screen and five percent passing a No. 4 sieve. (Ord. 5-1988 § 1 (part); Development Code 4-3-5)